

LINDSTROM, DIESSNER & CARR, P.C. Engineering * Surveying *

Engineering Surveying 136 Drum Point Road, Brick, New Tel (732) 477-8900 Fax (732) 477-8026

Storage Calculations

JOB NAME: 812 Main Avenue JOB NUMBER: 23074 CALCULATED: KCS DATE: 01/10/24

V = Impervious Area x Rainfall Depth

V = Volume (CF)

A= Drainage Area =

D = Rainfall Depth (in)	2-Year 3.5	10-Year 5.44	100-Year 7.34
Stormwater Runoff Calculations (CF)			
	Q(2-year)	Q(10-year)	Q(100-year)
Q (Post Construction)	467	725	979
Area of 6" Pipe (Within Driveway Only)	0.196	SF	
Length of Pipe	45	. –	
(Driveway Only)	45	LF	
Volume of Pipe (CF)	9	CF	
Volume of Stone (Driveway Only) Volume of Stone minus Pipe Voids	1500 1491 40%	-	
Volume of Stone (Driveway Only) Total Volume (Driveway Only)	596 605	•	
	605>467	ОК	